Dian Artanto

Improved Control

ek AI Part 3 (Moodle TT)

Praktik Komunikasi Data dan Jaringan Komputer B (MEKA I/2024/2025) (Moodle TT)

Universitas Sanata Dharma

Document Details

Submission ID trn:oid:::1:3028056408

Submission Date Oct 2, 2024, 3:09 PM GMT+7

Download Date Oct 2, 2024, 3:12 PM GMT+7

File Name

8229_Dian_Artanto_Improved_Control_970192_630870001.pdf

File Size

538.1 KB

10 Pages

4,439 Words

24,141 Characters

0% detected as AI

The percentage indicates the combined amount of likely AI-generated text as well as likely AI-generated text that was also likely AI-paraphrased.

Caution: Review required.

It is essential to understand the limitations of AI detection before making decisions about a student's work. We encourage you to learn more about Turnitin's AI detection capabilities before using the tool.

Detection Groups

1 AI-generated only 0% Likely AI-generated text from a large-language model.

2 AI-generated text that was AI-paraphrased 0% Likely AI-generated text that was likely revised using an AI-paraphrase tool or word spinner.

Disclaimer

Our AI writing assessment is designed to help educators identify text that might be prepared by a generative AI tool. Our AI writing assessment may not always be accurate (it may misidentify writing that is likely AI generated as AI generated and AI paraphrased or likely AI generated and AI paraphrased writing as only AI generated) so it should not be used as the sole basis for adverse actions against a student. It takes further scrutiny and human judgment in conjunction with an organization's application of its specific academic policies to determine whether any academic misconduct has occurred.

Frequently Asked Questions

How should I interpret Turnitin's AI writing percentage and false positives?

The percentage shown in the AI writing report is the amount of qualifying text within the submission that Turnitin's AI writing detection model determines was either likely AI-generated text from a large-language model or likely AI-generated text that was likely revised using an AI-paraphrase tool or word spinner.

False positives (incorrectly flagging human-written text as AI-generated) are a possibility in AI models.

AI detection scores under 20%, which we do not surface in new reports, have a higher likelihood of false positives. To reduce the likelihood of misinterpretation, no score or highlights are attributed and are indicated with an asterisk in the report (*%).

The AI writing percentage should not be the sole basis to determine whether misconduct has occurred. The reviewer/instructor should use the percentage as a means to start a formative conversation with their student and/or use it to examine the submitted assignment in accordance with their school's policies.

What does 'qualifying text' mean?

Our model only processes qualifying text in the form of long-form writing. Long-form writing means individual sentences contained in paragraphs that make up a longer piece of written work, such as an essay, a dissertation, or an article, etc. Qualifying text that has been determined to be likely AI-generated will be highlighted in cyan in the submission, and likely AI-generated and then likely AI-paraphrased will be highlighted purple.

Non-qualifying text, such as bullet points, annotated bibliographies, etc., will not be processed and can create disparity between the submission highlights and the percentage shown.

International Journal of Electrical and Computer Engineering (IJECE) Vol. 11, No. 4, August 2021, pp. 3003~3012 ISSN: 2088-8708, DOI: 10.11591/ijece.v11i4.pp3003-3012

Improved control and monitor two different PLC using LabVIEW and NI-OPC server

Ignatius Deradjad Pranowo, Dian Artanto

Mekatronika, Fakultas Vokasi, Universitas Sanata Dharma, Yogyakarta-Indonesia

Article Info

Article history:

Received Sep 17, 2020 Revised Dec 16, 2020 Accepted Jan 13, 2021

Keywords:

LabVIEW NI OPC server PLC

ABSTRACT

This paper proposes an improved control and monitors between two different PLCs, the Mitsubishi, and Omron. The main advantage is interoperability and communication between both PLC. The use of NI OPC server as the software interface reached interoperability and communication. There were developed two field applications to test interoperability. Laboratory virtual instrument engineering workbench (LabVIEW) uses as the software application for creating the user interface to control and monitor. This improvement show OPC server technology solves data compatibility issue between different driver controller's and reducing development cost. Regardless of whether there are more than two different PLCs, it's enough to use the NI OPC server. So the benefit of the NI OPC server is not limited to two types of PLC used right now but can also use the other manufacturers. Besides, the improvement of the previous study is the use of the LabVIEW makes data from the OPC server displayed more realistic. The use of LabVIEW allows additional monitoring functions, one of which is LabVIEW vision. Data utilization becomes more flexible, and so it can use for more complex purposes. It is envisaged that this is very useful for Integrator engineer to implement this method in industrial automation.

This is an open access article under the <u>CC BY-SA</u> license.



Corresponding Author:

Ignatius Deradjad Pranowo Mekatronika, Fakultas Vokasi Universitas Sanata Dharma Yogyakarta-Indonesia Email: dradjad@pmsd.ac.id

1. INTRODUCTION

System integration requires a tremendous exertion, particularly for enormous scope infrastructures. All in all, these facilities include an immense number of devices and applications with various communication conventions. In a system that utilizes a few distinct devices and must exchange information, they should gather, break down, and show information from different devices utilizing various conventions. This assignment isn't simple. Each device driver requires software from its vendor. Changes in convention determinations bring about communication failure, and modifications must be made.

This problem must be solved when confronting the plan and systems integration of infrastructures under cutting edge draws near. The choice of communication interface to accomplish a successful interoperability and heterogeneity the executives is an extraordinary choice that truly influences perspectives, for example, financial costs, viability, expand-ability, security, and versatility [1]. In this sense, OLE-object linking embedded-for process control (OPC) proved as an effective communication middle-ware mainly in industrial application. OPC provides technology to support interoperability and heterogeneity in control and automation applications, mainly devoted to industrial manufacturing [2]. The so-called classic OPC was

Journal homepage: http://ijece.iaescore.com

ISSN: 2088-8708

developed by the industrial automation industry task force in 1996 to provide communication protocol for the personal computer-based software applications and automation hardware [3].

OPC, as a standard interface, can communicate between numerous data sources, including devices in a factory, laboratory equipment, and database. There are a large number of papers reporting OPC applications. Each one of them focuses on specific features, just to name some are hardware in the loop [4], remote laboratory [5-8], share workspace [9, 10], SCADA and PLC [11, 12], process control data acquisition and monitoring [13-17].

The new enhancements made in the automation of the industrial processes were realized through integration among OPC PLC and LabVIEW. The OPC provides open connectivity meanwhile, PLC from the different manufacturers can communicate, and LabVIEW provides the user interface so the operator can easily control and monitor the applications system. Just to mention some previous works of the integration among OPC PLC and LabVIEW are [18-23]. Despite the numerous works carried out on the same subject, none investigated the interoperability and connectivity between two PLC different protocols or manufacturers.

This paper provides system control and monitoring between two different PLCs using OPC and LabVIEW. The current study contributes to the knowledge expansion in this field by addressing process control available in communication between Mitsubishi and Omron PLC based on OPC technology and LabVIEW user interface. The organization of the paper is as follows. The method of communication between two PLC different protocols (Mitsubishi and Omron) using NI-OPC server and LabVIEW explain in section 2. The result and discussion of this study provide in section 3 and section 4, respectively. In section 5 gives a sum of the conclusion.

2. METHOD

The primary commitment of the current work was the upgrade of interoperability and connectivity between two PLC various protocols and vendors, in view of OPC and LabVIEW. The experimental work was designed and set up among the sequence of NI-OPC server, PLC, and LabVIEW. Table 1 gives the exposed experiment pointing out the field application system, the OPC role, the software involved for both client and server, and the hardware appliances.

Table 1. The experimental OF C-based systems developed	Table 1. The	experimental	OPC -based	systems	develope	ed
--	--------------	--------------	-------------------	---------	----------	----

Field application system	OPC role	OPC server	OPC client	Hardware
Bottle Unscrambling	Control & monitoring, Interface connectivity	NI OPC server	LabVIEW	Mitsubishi PLC FX3U, Windows-based PC
Bottle Filling	Control & monitoring,	NI OPC server	LabVIEW	Omron PLC CP1E,
Dottite I ming	Interface connectivity	111 01 0 501701	Eac TE	Windows-based PC

2.1. NI-OPC server and LabVIEW

The utilization of the OPC interface prompted by demand of using PLC Mitsubishi and Omron also the SCADA system established in LabVIEW. Thanks to the proficiency of the OPC, their integration was easy and effective. Such systems reveal the OPC standard as an effective tool of integration of networks of controllers, sensors, and instruments regardless of the automated process. As a rule, the capacity of an OPC is to get to the information of a field device and make them available to OPC clients, i.e., programming applications that speak to activities with such information. In this work, the NI OPC server 2013 is utilized to set up an OPC server. To do this, among other parameters to be enumerated, the used addressed in the PLC memory the format of the data and the type of access. A PC, with OS Windows 10 Professional and Intel i3 CPU, pursues as the hosting of the NI-OPC server 2013, the LabVIEW 2015 application, and the software for the configuration of the PLC.

National instruments LabVIEW package is a powerful graphical language with an impressive builtin function. LabVIEW 2015 utilized to configure the virtual instrument (VI) as the OPC Client of the OPC server depicted formerly. The variables transferred by such an OPC Server added to the library of a VI, so controls and indicators connected to them. Indicators related with signals that read from the PLC, controls used to create variables to the PLC [8]. Accordingly, the collected values available for operations commanded from the LabVIEW Front panel, then imported the controls and indicators. The LabVIEW connector element is required, so it has to be continued and configured in the LabVIEW front panel. The NI-OPC server published the controls and indicators of the VI, then the LabVIEW connector ready to import and link them to the corresponding variables in the LabVIEW front panel. By this path, the instructions renewed those controls and indicators. The selection of LabVIEW is not only intended to facilitate data visualization but also because of the additional functions, one of which is LabVIEW vision. LabVIEW vision can be used to

Int J Elec & Comp Eng

ISSN: 2088-8708

3005

inspect field applications, such as detecting the presence or absence of labels and bottle caps. In general, the LabVIEW vision works by comparing the images taken by the camera with the images used as template patterns. LabVIEW vision will output the similarity level of the two images. By setting the similarity level limit, an application will be generated that can detect the presence or absence of certain parts of the field application. All image processing features are provided. Users don't need to do complicated programming, just take the desired feature (in the form of an icon), and add it to the image. The results obtained by adding these features are also shown on the screen so that users can adjust the results according to what they want [24].

2.2. PLC and field application

In signal management relate to the PLC's digital input and output ports, sensors and actuators were exploited to acquire signals in the automation process. Such PLC controlled the field application. The Omron controlled the bottle filling process, and Mitsubishi controlled the bottle unscrambling process. Each PLC has software from its manufacturer, Omron-CP1E used CX-Programmer and Mitsubishi-FX3U used GXWork2.

Both field applications were connected to the PC using a USB cable. The connection between PLC and OPC server used the RS232 Serial. The PLC was configured as a new OPC to communicate with the NI-OPC server. This leads to adding client access to the server. The Path makes a chance for OPC Client to access all PLC registers. In the LabVIEW, a VI created to connect OPC server [23].

2.3. Proposed architecture

Figure 1 brings the block diagram of the system exploited the interconnection between two different PLC protocols. OPC technology is utilized in this situation using NI-OPC server and augmented the benefit of LabVIEW as a control and monitoring system function. Interconnection between Mitsubishi FX3U and Omron CP1E is made feasible by the role of the NI-OPC server without the need to synchronize the two controllers or contribute each protocol from the respective vendors.

The experimentation setup for controlling and monitoring of two different PLCs OPC based was proposed as shown in Figure 2. This work used two field applications, namely bottle unscrambling and bottle filling. Both of the field applications can communicate through NI-OPC server with some variable settings. Through these arrangements, the filling water process will happen if bottles delivered from the bottle unscrambling process have aligned to with position the bottle's head is above. This data got since the bottle filling controller read data from sensors as a result of the presence detection of the bottles sent from the bottle unscrambling process is full, and it will reactivate if the queue reduced or depend on the PLC program [25].



Figure 1. Block diagram of the proposed architecture



Figure 2. Experimentation setup of the control and monitor two-PLC based on OPC

Improved control and monitor two different PLC using LabVIEW... (Ignatius Deradjad Pranowo)

ISSN: 2088-8708

3. **RESULTS**

In the OPC standard, this client-server communication is the significant key of the entire framework. The client application is not associated with device management. The server application is answerable for dealing with the device utilizing a standard interface. Equipment suppliers and programming designers can emerge from different vendors. LabVIEW gives two answers for associating OPC clients to the OPC framework: i) Running LabVIEW DataSocket in the LabVIEW advancement framework, ii) Running the LabVIEW DSC module. This work embraces the principal answer for making a thing of OPC Client. By utilizing the front panel information joining capacity, objects (buttons, indicators, and so forth) can be connected to things in the OPC server through the DataSocket server. Subsequently, the trial procedure control in the LabVIEW application is made through the element item, which is designed on the server. Figure 3 outlines the nearby OPC framework utilized for communication between LabVIEW and PLC applications. The PLC communicates with the OPC server through the Serial port. At the point when the OPC server gets PLC information through the Serial port, the information is changed over to a standard OPC position that can be gotten to by the OPC client. OPC client can understand information and compose new information to the device by utilizing OPC server [26]. In this work, the names of NI OPC server tags were set up, following the input-output made on the Mitsubishi and Omron PLC programs. The first is the procedure for how to set up communication on the NI-OPC server, and then the second is the procedure for how to communicate between LabVIEW and the NI-OPC server.



Figure 3. OPC for communication between LabVIEW and PLC

3.1. Steps for communication settings on NI-OPC server

The steps for communication settings on the NI-OPC server are as:

- Open NI-OPC server 2015.
- Since there are two PLC connected, create 2 channels on the NI-OPC server. Name both channels according to the PLC name.
- Add to each channel the type of PLC model used. For Mitsubishi PLC type "FX" and for Omron PLC type "CP1E".
- Add a tag to each type of PLC according to the input-output device connected to it. For Mitsubishi PLC add six tags, namely "Motor1", "Motor2", "Motor3", "Solenoid", "Start1" and "Stop1" as shown in Figure 4. For Omron PLC add seven tags, namely "Counter", "EmergencyStop", "Reset", "Start", "Stop", "StopKom" and "StopProses" as shown in Figure 5.

0 🗃 🖬 🖬	🔊 🛅 🚳	23	5 X G	8. × 99				
₽ 🍄 MITSUBISHI □ 🛗 FX □ III OMRON			Tag Na /	Address	Data Type	Scan Rate	Scaling	Description
			MOTOR1	1 M0006 2 M0007	Boolean Boolean	100 100	None None	
			MOTOR2					
CP1E			MOTOR3	M0008	Boolean	100	None	
			SOLENOID	M0010	/10010 Boolean	100 100	None None	
			START1	M0001	Boolean			
			STOP1	M0002	Boolean	100	None	
🖣 🤌 🖗								
Date 🗸	Time	Source	Even	t			1	
7/6/2020 7/6/2020	2:30:32 PM 2:31:39 PM	NI OPC	Servers Cont Servers Cont	figuration sestinguration sest	sion started by U sion assigned to	ser <mark>as</mark> Default U User as Default	lser Us	

Figure 4. Six tags correspond to the I/O devices connected to the Mitsubishi PLC FX3U

Int J Elec & Comp Eng

ISSN: 2088-8708

3007

0 💕 🖬 🖬	9 🖬 🖻	2 🕾	5 %	百 邑 ×	GC				
∰ MITSUBISHI ∰ DMRON ∰ CP1E 			Tag Na	me /	Address	Data Type	Scan Rate	Scaling	Descriptio
		COUNTER MEMERGENCYSTOP RESET START STOP STOPROM STOPPROSES		C0006 C100200.09 C100200.05 C100200.03 C100200.04 C100200.07	BCD Boolean Boolean Boolean Boolean Boolean	100 100 100 100 100 100 100	None None None None None None None		
				W000.06	Boolean				
		٢						,	
Date 7	Time	Source		Event					,
1 7/6/2020	2:30:32 PM 2:31:39 PM	NI OPC	Servers Servers	Configuration Configuration	n session starte n session assig	ed by User as D ned to User as I	efault User Default Us		

Figure 5. Seven tags correspond to I/O devices connected to the Omron PLC CP1E

- Run "OPC Quick Client". In the "OPC Quick Client" window, select the "Mitsubishi.FX" folder as shown in Figure 6. If the connection and driver selection are correct then the quality column on all tags will display the status "Good". Likewise, for the "Omron.CP1E" folder the quality column in all tags should display the status "Good" as shown in Figure 7.

	and the second se	item ID	/ Data Type	Value	Timestamp	Quality	Update Count
🛅 _System	0	MITSUBISHLFX.MOTOR1	Boolean	0	14:44:05.371	Good	1
- C MITSUBISHI, Statistics	6	MITSUBISHI.FX.MOTOR2	Boolean	0	14:44:05.371	Good	1
🛅 MITSUBISHISystem	0	MITSUBISHLEX.MOTOR3	Boolean	0	14:44:05.371	Good	1
MITSUBISHLEX		MITSUBISHLEX.SOLENOID	Boolean	0	14:44:05.371	Good	1
- MITSUBISHI.FX_Statistics		MITSUBISHI.FX.STARTI	Boolean	0	14:44:05.371	Good	1
MITSUBISHLEX, System OMRON_Statistics OMRON_System OMRON_System OMRON_CP1E OMRON_CP1F, Statistics	~	MITSUBISHLEX.STOP1	Boolean	0	14:44:05.371	Good	1

Figure 6. The OPC quick client shows the status of all tags from Mitsubishi FX is good

Rational In	struments.NIOPCServers.V	5 ^	Item ID /	Data Type	Value	Timestamp	Quality	Update Count
- 🖾 _System	n		COMPON.CP1E.COUNTER	Word	5	14:44:19.533	Good	2
- 🔲 MITSUR	SISHL_Statistics		COMRON.CP1E.EMERGENCYSTOP	Boolean	0	14:44:19.656	Good	2
	BISHL_System		COMRON.CP1E.RESET	Boolean	0	14:44:19.656	Good	2
MITSUE	RISHLIFX		CMRON.CP1E.START	Boolean	0	14:44:19.656	Good	2
- MITSUE	SISHLEX. Statistics		COMRON.CP1E.STOP	Boolean	1	14:44:19.656	Good	2
- MITSUE	SISHLEX. System		COMPON.CP1E.STOPKOM	Boolean	0	14:44:19.656	Good	2
🛅 OMRO 🛅 OMRO 🎒 OMRO 😭 OMRO	N. Statistics N. System N.CP1E N.CD1F. Statistics	, [~]	CMRON.CP1E.STOPPROSES	Boolean	0	14:44:19.779	Good	2
Date	Time	Eve	nt					
0 7/7/2020 0 7/7/2020	2:44:05 PM	Con	inected to server 'National Instruments. led proup 'System' to 'National Instrum	NIOPCServers.	V5',			

Figure 7. The OPC quick client shows the status of all tags from Omron CP1E is good

3.2. Steps to connect LabVIEW with NI-OPC server

The steps for connecting LabVIEW with NI-OPC server are as follows:

- Create a "new project" on LabVIEW.
- In the "new project" window, right-click on "My Computer" then select "New" "I/O Server" as shown in Figure 8.
- In the "Create New I/O Server" window, select "OPC Client" then click "Continue"

Improved control and monitor two different PLC using LabVIEW... (Ignatius Deradjad Pranowo)

ISSN: 2088-8708

3008 🗖

- In the "OPC Server list" select "National Instruments.NIOPCServers.V5"
- In the "new project" window, right-click on "OPC1 object" and select "Create New Bound" to create a variable in LabVIEW that corresponds to all the tags on NI OPC server. For tags Mitsubishi, go to "OPC1-Mitsubishi-FX" shown in Figure 9. For tags Omron, go to "OPC1-Omron-CP1E" as shown in Figure 10. Select all the tags and then click "Add" button to create variables for them in LabVIEW. The variable with the same name as the tags will appear under the OPC1 folder in the New Project window.
- The next step is to display the variable data and process it in the LabVIEW program as shown in Figures 11 and 12.



Figure 8. Connecting LabVIEW with NI-OPC server through I/O server

No CALLY DO NUMBER OF A MARKED	Browse Source		Added variables	
Image: Section of the section of th	Project hems → Project IN OPC SERVER 7 JUN → → My Computer ← DNIOPCSERVEROLMIB ← MOVERSERVEROLMIB ← MIDELENT ← MIDELEN	Add >> Add range >> Custom-base name Variable Copy properties from Browse	MOTORI MOTORS SOLENDIO STARTI STOPI	

Figure 9. Creating variables associated with all Mitsubishi PLC tags on the NI OPC server



Figure 10. Creating variables associated with all Omron PLC tags on the NI OPC server

Int J Elec & Comp Eng

ISSN: 2088-8708

3009



Figure 11. Variables data associated with OPC tags in the LabVIEW



Figure 12. Variables data associated with the OPC server tag in the LabVIEW

As a result, monitoring and controlling of two PLCs became easy by using NI-OPC server and LabVIEW. In the NI OPC server there is a facility for setting or selecting various PLC drivers start from Allen Bradley, Beckhoff, GE, Honeywell, Mitsubishi, Omron, Siemens, Telemecanique, Toshiba. So that the efficacy of the NI OPC server is not only limited to the two types of PLC used in this paper. In addition, the improvement from the previous study is data from OPC server can be displayed and visualized more realistically using the LabVIEW program; and data utilization becomes more flexible which can be used for more complex purposes as shown in Figure 13. In this work, the bottle cap detection application has implemented using LabVIEW Vision and a webcam. By using LabVIEW vision, we can monitor workpieces and even labels; so that monitoring can cover all aspects, not only counting the quantity but also the condition of the product. Figure 14 shows that LabVIEW Vision will be able to detect the bottle cap if there is a manual bottle cap feeding process.

Improved control and monitor two different PLC using LabVIEW... (Ignatius Deradjad Pranowo)



ISSN: 2088-8708



Figure 13. The result of display in LabVIEW according to the actual physical conditions on the field application



Figure 14. The LabVIEW vision application display for bottle cap detection

4. **DISCUSSION**

In several previous papers have discussed the use of OPC server. All references in this work using the OPC server for data acquisition and interconnection between different controllers. These references use the PLC as a controller, but none are from different manufacturers. There is a reference [27] using two PLCs, but it comes from one manufacturer. Therefore, the use of OPC server has become less exposed. Solely reference [25] indeed used two different PLC types, but having a limitation in the client program not upheld by the user interface to control and monitor quickly. In any case, this was better than simply applying a PLC to perform the heterogeneity and interconnectivity in control and automation applications. Table 2 provides some related works heretofore, with its focus on the type of OPC software used, the type of protocol communication used, and the hardware used.

3011

Table 2. Selected papers of the related works								
Related works [ref.]	OPC software	Communication protocol	Hardware (PLC)					
González I et al. [8]	NI-OPC server LabVIEW, JIL (client)	Ethernet/PROFINET	Siemens S7-1200					
Şahin C. and Bolat E. D. [19]	OPC server Delphi (client)	RS232 ASP-Internet	Siemens S7-200					
Lakshmi S. A et al. [23]	RSView 32 SCADA	RSLinx-TCP/IP	Micrologix-1200					
Pranowo I. D et al. [25]	KEPServerEx6	RS232	Mitsubishi FX3U Omron CP1E					
Aleksandrov S et al. [27]	OPC Easy server LabVIEW (client)	LAN-TCP/IP	Festo FC-34 Festo FC-640					
Nithyarani N. [28]	NI-OPC server LabVIEW (client)	Ethernet-TPC/IP	Honeywell HC900-C30					
This work	NI-OPC server LabVIEW (client)	RS232	Mitsubishi FX3U Omron CP1E					

Figure 13 approved that the improved control and monitoring between two PLC different protocols using NI-OPC server and LabVIEW user interface can be done. The developed control and monitoring system has two selection modes, namely the manual and the automatic. In automatic mode, when the Start button is squeezed, the system will run consistently starting from the bottle adjusting process until the bottle filling process and stop only when the Stop button is squeezed. This can happen due to the capacity of the NI-OPC server as a scaffold for the two PLC with various protocols, so they can impart without paying attention to the drivers of the two software.

In accordance with the title of this paper, the tools for improving control and monitor here is not only using NI-OPC but also using LabVIEW software. LabVIEW software was chosen because this software provides strong support and easy connection with various hardware devices. With many additional features in LabVIEW, one of which is LabVIEW Vision, it allows a lot of development to be done. In this study, the LabVIEW Vision and a webcam have implemented to detect the bottle cap. In addition, the LabVIEW graphical programming language makes it easier to implement the program even for inexperienced. This is the idea proposed in this paper.

5. CONCLUSION

The goal of this work proposes an improved control and monitors between two PLC various controllers in the modern manufacturing process. This study has successfully exhibited the strength of the NI-OPC server in communicating two different PLC protocols particularly between Mitsubishi FX3U and Omron CP1E. This work has been boosted an advantage in controlling and monitoring through the functions contributed by the LabVIEW user interface. In this work, the use of two different PLC Mitsubishi FX3U and Omron CP1E contributes a precise figure of the benefits of OPC server technology. What has become an improvement from previous work is the more realistic OPC tag data visualization and more flexible data utilization using LabVIEW. Also, the use of LabVIEW allows the addition of many controls and monitoring features, one of which is LabVIEW vision, which can perform inspection functions on the field application. Because of the utilization of NI-OPC server and LabVIEW, the advancement cost investment funds in the modern manufacturing process will be more proficient. Say if, for two different types of PLC manufacturers can be handled by the software interface, namely NI-OPC server. If there are more than two, it is sufficient to utilize the software. So, it is an outstandingly away from the level of the venture finances will be gotten. In spite of field application was a prototype, but this work used the PLC as a genuine industrial device on automation. Further work ought to be done, structure up the web base, so the communication among the controllers can be observed and controlled remotely.

REFERENCES

- [1] González, I., Calderón, A. J., Figueiredo, J., and Sousa, J., "A literature survey on open platform communications (OPC) applied to advanced industrial environments," *Electronics*, vol. 8, no. 5, pp. 510, 2019.
- [2] Elliott, C., Vijayakumar, V., Zink, W., and Hansen, R., "National Instruments LabVIEW: A Programming Environment for Laboratory Automation and Measurement," *Journal of the Association for Laboratory Automation*, vol. 12, no. 1, pp. 17-24, 2008.
- [3] "OPC Foundation Home Page," 2020. [Online]. Available: https://opcfoundation.org/.
- [4] Jacob M. and Andreescu G. D., "Implementation of hardware-in-the-loop system for drum-boiler-turbine decoupled multivariable control," 2011 6th IEEE International Symposium on Applied Computational Intelligence and Informatics (SACI), Timisoara, Romania, 2011, pp. 45-50.

Improved control and monitor two different PLC using LabVIEW... (Ignatius Deradjad Pranowo)

ISSN: 2088-8708

- [5] Vadi S., "Development of an OPC and PLC Based Remote-Access Laboratory: A Synchronous Motor Control Experiment," *International Journal of Applied Mathematics Electronics and Computers*, vol. 3, no. 3, pp. 172-177, 2015.
- [6] Calvo, I., Zulueta, E., Oterino, F., & Lopez-Guede, J. M., "A Remote Laboratory for a Basic Course on Control Engineering," *International Journal of Online Engineering (iJOE)*, vol. 5, no. 3, pp. 8-13, 2009.
- [7] Klein A. and Wozny G., "Web Based Remote Experiments for Chemical Engineering Education: The Online Distillation Column," *Education for Chemical Engineers*, vol. 1, no. 1, pp. 134-138, 2006.
- [8] Gonzalez, I., Calderon, A. J., Mejias, A., and Andujar, J. M., "Novel networked remote laboratory architecture for open connectivity based on PLC-OPC-LabVIEW-EJS integration. Application in remote fuzzy control and sensors data acquisition," *Sensors*, vol. 16, no. 11, 2016, Art. no. 1822.
- [9] Schaf, F. M., Müller, D., Bruns, F. W., Pereira, C. E., and Erbe, H. H., "Collaborative learning and engineering workspaces," *Annual Reviews in Control*, vol. 33, no. 2, pp. 246-252, 2009.
- [10] Balaji A. and G. A. R., "Design of LabVIEW Based SCADA System for Pneumatics Applications," International Journal of Scientific Research in Science and Technology, vol. 3, no. 8, pp. 148-154, 2017.
- [11] Toylan H. and Kuscu H., "A research on SCADA application by the help of OPC server for the water tank filling system," *Scientific Research and Essays*, vol. 5, no. 24, pp. 3932-3938, 2011.
- [12] González, I., Calderón, A. J., Barragán, A. J., and Andújar, J. M., "Integration of sensors, controllers and instruments using a novel OPC architecture," *Sensors*, vol. 17, no. 7, 2017, Art. no. 1512.
- [13] Mahmoud M. S., Sabih M., Elshafei M., "Using OPC technology to support the study of advanced process control," *ISA Transactions*, vol. 55, pp. 155-167, 2015.
- [14] Zhu, M., Lu, S., Du, H., and Zhu, Z., "Design and application of field equipment information system based on OPC," *IECON 2017 - 43rd Annual Conference of the IEEE Industrial Electronics Society*, Beijing, 2017, pp. 7422-7426.
- [15] Zhang Y., Liu M., Zhao F., "The design and implementation of PLC monitoring system based on OPC," Applied Mechanics and Materials, vol. 278-280, pp. 930-935, 2013.
- [16] Nicola, M., Nicola, C. I., Sacerdoțianu, D., and Duță, M., "SCADA systems architecture based on OPC Servers and applications for industrial process control," *International Journal of Control Science and Engineering*, vol. 8, no. 1, pp. 13-21, 2018.
- [17] Hong X. and Jianhua W., "Using standard components in automation industry: A study on OPC specification," *Computer Standards & Interfaces*, vol. 28, no. 4, pp. 386-395, 2006.
- [18] Panchal P., Patel A., Barve J., "PI control of level control system using PLC and LabVIEW based SCADA," 2015 International Conference on Industrial Instrumentation and Control (ICIC), Pune, India, 2015, pp. 1196-1201.
- [19] Şahin C. and Bolat E. D., "Development of remote control and monitoring of web-based distributed OPC system," *Computer Standards and Interfaces*, vol. 31, no. 5, pp. 984-993, 2009.
- [20] Ashraf M. N., Khalid S. A. Bin, Ahmed M. S. et al., "Implementation of Intranet-SCADA using LabVIEW based data acquisition and management," 2009 International Conference on Computing, Engineering and Information, Fullerton, CA, USA, 2009, pp. 244-249.
- [21] Singh R., Patel A., Dalwadi N., "Driver Development of Mitsubishi FX-PLC for LabVIEW," 2017 International Conference on Inventive Systems and Control (ICISC), Coimbatore, 2017, pp. 1-5.
- [22] Akshay, N., Sravanth, K. U., Varanasi, R., and Reddy, J. A., "Real Time Automated Control of Industrial Processes with PLC-LabVIEW Communication," *International Journal for Research in Science & Advanced Technologies*, vol. 1, no. 1, pp. 35-38, 2012.
- [23] Sangeetha, A. L., Naveenkumar, B., Ganesh, A. B., and Bharathi, N., "Experimental validation of PID based cascade control system through SCADA-PLC-OPC and internet architectures," *Measurement*, vol. 45, no. 4, pp. 643-649, 2011.
- [24] Pokharel B., "Machine Vision and Object Sorting," HAMK University of Applied Sciences, 2013.
- [25] Pranowo I. D., Bagastama Y. B. T., Wibisono T. A. F., "Communication between PLC different vendors using OPC server improved with application device," *TELKOMNIKA Telecommunication Comput Electron Control*, vol. 18, no. 3, pp. 1491-1498, 2020.
- [26] Wang, J., Zhong, S., Li, X., and Wang, F., "Development of 20 liter spherical explosion test apparatus based on LabVIEW and OPC technique," 2010 Chinese Control and Decision Conference, Xuzhou, China, 2010, pp. 4262-4266.
- [27] Aleksandrov, S., Jovanović, Z., Nikolić, S., and Čajetinac, S., "Mechatronic Systems Control Based on SCADA, OPC Server and LabVIEW," FACTA UNIVERSITATIS Series: Automatic Control and Robotics, vol. 10, no. 2, pp. 189-198, 2011.
- [28] N. Nithyarani, "Implementation of OPC-Based Communication Between Temperature Process and DCS on Labview Platform," *BEST International Journal of Management, Information Technology and Engineering (BEST IJMITE)*, vol. 1, no. 1, pp. 51-60, 2013.